



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13074-52-227
State Number
19198

EQUIPMENT INSPECTED

State Number: 19198	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 12/08/2000	Rope Size: 0
Volts: 480	Complied: 12/14/2000	Entrances: 1
OWNER	OCCUPANT	
AVERY COUNTY SCHOOLS	NEW CROSSNORE ELEMENTARY	
P.O. BOX 1360	1000 WALT CLARK ROAD	
NEWLAND, NC, 28657	CROSSNORE, NC, 28616	

INSPECTION INFORMATION

Inspection Date 03/15/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

8.11.3.2.1	Perform the annual relief valve and system pressure test.
8.6.1.7.2	Provide proper metal tag to the controller for all periodic tests.

Items must be corrected by: 04/14/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: New Crossnore Elementary 828-733-6006

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AVERY COUNTY SCHOOLS
P.O. BOX 1360
NEWLAND, NC, 28657