



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**13078-48-1986**  
State Number  
**21788**

EQUIPMENT INSPECTED

State Number: <b>21788</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 06/25/2003	Rope Size: 0
Volts: 208	Complied: 06/25/2003	Entrances: 1
OWNER	OCCUPANT	
SHALLOTTE PRESBYTERIAN CHURCH	SHALLOTTE PRSBYTERIAN CHURCH	
POB 251; 5070 ROURK DR	5070 ROURK DRIVE	
SHALLOTTE, NC, 28459	SHALLOTTE, NC, 28459	

INSPECTION INFORMATION

Inspection Date 03/19/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: CASEY

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SHALLOTTE PRESBYTERIAN CHURCH  
POB 251; 5070 ROURK DR  
SHALLOTTE, NC, 28459