



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13092-48-1547
State Number
25981

EQUIPMENT INSPECTED

State Number: 25981	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: TKE	Speed: 130
Landings: 2	Installed: 01/27/2009	Rope Size:
Volts: 200	Complied: 01/27/2009	Entrances: 1
OWNER	OCCUPANT	
DIXIE GENERAL CONTRACTORS	HOLDEN BEACH NEW TOWN HALL	
1236 N TEACHY ROAD	110 ROTHSCHILD STREET	
WALLACE, NC, 28466	HOLDEN BEACH, NC, 28462	

INSPECTION INFORMATION

Inspection Date 04/02/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.11.2.2.2 Perform the annual no load safety test

Items must be corrected by: 05/02/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Heather

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DIXIE GENERAL CONTRACTORS
1236 N TEACHY ROAD
WALLACE, NC, 28466