



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**13094-48-1975**  
State Number  
**26754**

EQUIPMENT INSPECTED

State Number: <b>26754</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 3500	Manuf: TKE	Speed: 80
Landings: 2	Installed: 07/10/2009	Rope Size:
Volts: 480	Complied: 07/10/2009	Entrances: 1
OWNER	OCCUPANT	
PENDER BOARD OF EDUCATION	NEW HANOVER REG. MEDICAL CENTER	
925 PENDERLEA HWY.	1333 S DICKINSON STREET	
BURGAW, NC,	LELAND, NC, 28451	

INSPECTION INFORMATION

Inspection Date 04/04/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 04/14/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Lana Kerry

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

PENDER BOARD OF EDUCATION  
925 PENDERLEA HWY.  
BURGAW, NC,