



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13095-52-0026
State Number
11189

EQUIPMENT INSPECTED

State Number: 11189	Type of Unit: Passenger	Floor to Floor: 2 to 3
Capacity: 2500	Manuf: ACE	Speed: 115
Landings: 3	Installed: 07/15/1986	Rope Size: 0
Volts: 208	Complied: 07/18/1986	Entrances: 1
OWNER	OCCUPANT	
N.C. WILDERNESS LIMITED	LINVILLE RIDGE CLUBHOUSE	
P.O. BOX 704	7000 RIDGE ROAD	
LINVILLE, NC, 28646	LINVILLE, NC, 28646	

INSPECTION INFORMATION

Inspection Date 04/05/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

- 2.13.5.1 Replace missing reflector for elevator reopening device.
- 2.9.1 Assign identification (numbers or letters) to the equipment where required. (Controller, inside elevator on car station and main lobby elevator door frame.
- 2.14.1.4.5 Put the in car stop switch in proper working order.

Items must be corrected by: 05/05/2013

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Linville Ridge Clubhouse 828-898-5151

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

N.C. WILDERNESS LIMITED
P.O. BOX 704
LINVILLE, NC, 28646