N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13098-17-4170
State Number
10680

EQUIPMENT INSPECTED

State Number: **10680**
Capacity: 2500
Landings: 6
Volts: 208

Type of Unit: Passenger
Manuf: ASHEVILLE
Installed: 03/01/1984
Complied: 01/12/2007

Floor to Floor: 1 to 6
Speed: 150
Rope Size:
Entrances: 1

OWNER
AMBICA LLC
PO BOX 2470
CANDLER, NC, 28715

OCCUPANT
HOLIDAY INN ASHEVILLE
435 SMOKEY PARK HWY
ASHEVILLE, NC, 28806

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
04/08/2013	Routine	Re-issued	17 - White	BUNCOMBE	11 A

VIOLATIONS

2.27	Provide a phase 1 sign.
8.6.4	Adjust car to rails.
nec	Properly mark pit stop switch in red and with lettering.
8.6.4	Clean pit.
8.11	Provide matching dates for annual hydraulic tests.

Items must be corrected by: 05/08/2013

Elevator Name: #2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Jackie 828-665-2161

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
AMBICA LLC
PO BOX 2470
CANDLER, NC, 28715