



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13098-17-5384
State Number
10681

EQUIPMENT INSPECTED

State Number: 10681	Type of Unit: Passenger	Floor to Floor: 1 to 6
Capacity: 2500	Manuf: ASHEVILLE	Speed: 150
Landings: 6	Installed: 03/09/1984	Rope Size: 0
Volts: 460	Complied: 03/09/1984	Entrances: 1
OWNER	OCCUPANT	
AMBICA LLC	HOLIDAY INN ASHEVILLE	
PO BOX 2470	435 SMOKEY PARK HIGHWAY	
CANDLER, NC, 28715	ASHEVILLE, NC, 28806	

INSPECTION INFORMATION

Inspection Date 04/08/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

2.27	Phase 1 sign
nec	Mark pit switch in red with lettering.
8.6.4	Adjust door gaps.
8.6.4	adjust car to rails.

Items must be corrected by: 05/08/2013

Elevator Name: 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: jackie

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AMBICA LLC
PO BOX 2470
CANDLER, NC, 28715