



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13099-36-2627
State Number
13709

EQUIPMENT INSPECTED

State Number: 13709	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 4000	Manuf: THYSSEN KRUPP	Speed: 80
Landings: 3	Installed: 09/19/1991	Rope Size:
Volts: 460	Complied: 02/07/1994	Entrances: 2
OWNER	OCCUPANT	
LAB CORP	LAB CORP	
ATTN STEVE THACKER	1447 YORK CT	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 04/09/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

none found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: DAVID STUBBLEFIELD 336-516-1117

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LAB CORP
ATTN STEVE THACKER
BURLINGTON, NC, 27215