N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13107-48-5563
State Number
26542

EQUIPMENT INSPECTED

State Number: **26542**
Capacity: 2500
Landings: 4
Volts: 208

Type of Unit: Passenger
Manuf: SCHINDLER
Installed: 04/02/2009
Complied: 04/02/2009

Floor to Floor: 1 to 4
Speed: 125
Rope Size:
Entrances: 1

OWNER
COASTAL HOSPITALITY LLC
1511 N HOWE STREET
SOUTHPORT, NC, 28461

OCCUPANT
SOUTHPORT WINGATE INN
1511 N HOWE STREET
SOUTHPORT, NC, 28461

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
04/17/2013	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.4.7.1	Clean the elevator pit.
N/A	LOOSE HANDRAIL IN CAR

Items must be corrected by: 05/07/2013

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: CRYSTAL

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
COASTAL HOSPITALITY LLC
1511 N HOWE STREET
SOUTHPORT, NC, 28461