



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**13120-48-4622**  
State Number  
**22892**

EQUIPMENT INSPECTED

State Number: <b>22892</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 03/02/2005	Rope Size: 0
Volts: 240	Complied: 03/02/2005	Entrances: 1
OWNER	OCCUPANT	
COMMUNITY ASSOCIATION MGMT.	VILLAS ON OSPREY RIDGE	
P.O. BOX 8126	182 CLUBHOUSE RD.	
OCEAN ISLE BEACH, NC, 28469	SUNSET BEACH, NC, 28468	

INSPECTION INFORMATION

Inspection Date 04/30/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.13.1[k] Properly maintain door closers, where required. Motor room door

Items must be corrected by: 05/20/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Unavailable

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

COMMUNITY ASSOCIATION MGMT.  
P.O. BOX 8126  
OCEAN ISLE BEACH, NC, 28469