



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13122-16-4364
State Number
N7.1

EQUIPMENT INSPECTED

State Number: N7.1	Type of Unit: Freight	Floor to Floor: B to 3
Capacity: 1500	Manuf: WESTBROOK	Speed: 100
Landings: 5	Installed: 05/21/1975	Rope Size: 5/8
Volts: 220	Complied: 05/21/1975	Entrances: 2
OWNER	OCCUPANT	
NORMAN MANNING	PHILLIPS WRIGHT FURNITURE CO.	
246 W MAIN ST.	246 W MAIN ST	
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 05/02/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

- 8.6.1.6.2 All parts of the machinery and equipment requiring lubrication shall be lubricated with lubricants equivalent manufacturers recommendations
- 8.6.4.10.1[c] Winding-drum driving-machines with 1:1 roping, if of the babbitted rope socket type, shall be resocketed, or for other type of fastenings, replaced or moved on the rope to a point above the existing fastening at the car ends
- 8.11.2.2.2 Perform the annual no load safety test

Items must be corrected by: 06/01/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Fredrick Switzer

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

NORMAN MANNING
246 W MAIN ST.
WASHINGTON, NC, 27889