



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**13122-16-5682**  
State Number  
**4769**

EQUIPMENT INSPECTED

State Number: <b>4769</b>	Type of Unit: Freight	Floor to Floor: 1 to 3
Capacity: 2700	Manuf: WESTBROOK	Speed: 75
Landings: 3	Installed: 09/26/1962	Rope Size: 1/2
Volts: 220	Complied: 09/26/1962	Entrances: 1
OWNER	OCCUPANT	
JAMES FORTESCUE	STAR CRAFT	
248 NANCE LAND	444 STEWART PKWY	
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 05/02/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

8.11.2.2.2 Perform an annual no load safety test and provide proper tags.

Items must be corrected by: 06/01/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jim Fortescue /

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

JAMES FORTESCUE  
248 NANCE LAND  
WASHINGTON, NC, 27889