



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13126-48-3699
State Number
27440

EQUIPMENT INSPECTED

State Number: 27440	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 3500	Manuf: SCHINDLER	Speed: 100
Landings: 2	Installed: 08/25/2010	Rope Size:
Volts: 208	Complied: 08/25/2010	Entrances: 1
OWNER	OCCUPANT	
ARBOR LANDING @ OCEAN ISLE LLC	ARBOR LANDING @ OCEAN ISLE	
853 OLD WINSTON RD STE 118	5521 BEECH DRIVE NW	
KERNERSVILLE, NC, 27284	OCEAN ISLE, NC, 28469	

INSPECTION INFORMATION

Inspection Date 05/06/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.5.9 Relief-Valve Setting. The relief-valve adjustment shall be examined to ensure that the seal is intact. If the relief-valve seal is not intact, checks shall be conducted in accordance with 8.11.3.2.1. [SEAL MISSING].

Items must be corrected by: 06/05/2013

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Mark

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARBOR LANDING @ OCEAN ISLE LLC
853 OLD WINSTON RD STE 118
KERNERSVILLE, NC, 27284