



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**13129-24-2830**  
State Number  
**10294**

EQUIPMENT INSPECTED

State Number: <b>10294</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: GENERAL	Speed: 100
Landings: 4	Installed: 07/09/1982	Rope Size:
Volts: 208	Complied: 07/09/1982	Entrances: 1
OWNER	OCCUPANT	
72 PATTON ASSOCIATES	72 PATTON ASSOCIATES	
72 PATTON AVENUE	72 PATTON AVENUE	
ASHEVILLE, NC, 28801	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 05/09/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

- 8.6.8.9 Signs. Caution signs shall be provided. Damaged or missing signs shall be replaced. Provide a sign on the elevator equipment room door.  
"AUTHORIZED PERSONNEL ONLY".
- 8.6.4.13.1[c] Properly maintain door reopening devices Photo-eyes are not operating. Repair or replace.

Items must be corrected by: 06/08/2013

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Linda English / 828-252-7381

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

72 PATTON ASSOCIATES  
72 PATTON AVENUE  
ASHEVILLE, NC, 28801