



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13130-24-5949
State Number
10537

EQUIPMENT INSPECTED

| | | |
|----------------------------|-------------------------|------------------------|
| State Number: 10537 | Type of Unit: Passenger | Floor to Floor: 1 to 2 |
| Capacity: 2100 | Manuf: GENERAL | Speed: 100 |
| Landings: 2 | Installed: 06/15/1983 | Rope Size: |
| Volts: 208 | Complied: 07/05/1983 | Entrances: 1 |
| OWNER | OCCUPANT | |
| ASHEVILLE CITY SCHOOLS | LUCY HERRING ADMIN BLDG | |
| PO BOX 7347 | 85 MOUNTAIN STREET | |
| ASHEVILLE, NC, 28802 | ASHEVILLE, NC, 28801 | |

INSPECTION INFORMATION

| | | | | | |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|------|
| Inspection Date 05/10/2013 | Type Inspection Routine | Certificate Status Re-issued | Inspector 24 - Moore | County BUNCOMBE | 11 B |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|------|

VIOLATIONS

8.6.8.9 Signs. Caution signs shall be provided. Damaged or missing signs shall be replaced. Provide a sign on the elevator equipment room door.
"AUTHORIZED PERSONNEL ONLY".

Items must be corrected by: 06/09/2013

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Dwayne Taylor / 828-350-7000

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE CITY SCHOOLS
PO BOX 7347
ASHEVILLE, NC, 28802