



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13134-17-1224
State Number
2324

EQUIPMENT INSPECTED

State Number: 2324	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 3000	Manuf: ACE	Speed: 50
Landings: 2	Installed: 05/10/1954	Rope Size:
Volts: 550	Complied: 05/10/1954	Entrances: 2
OWNER	OCCUPANT	
ASC BUSINESS PARK LLC	BLUE RIDGE BUSINESS CENTER	
128 BINGHAM RD	128 BINGHAM RD	
ASHEVILLE, NC, 28806	ASHEVILLE, NC, 28806	

INSPECTION INFORMATION

Inspection Date 05/14/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

3.24.2.1 Add the correct amount of oil to the pumping unit reservoir.
note Unit is a pre 1973 so it has to have a biannual pressure test.

Items must be corrected by: 06/13/2013

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Josh Clark 828-280-3648

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASC BUSINESS PARK LLC
128 BINGHAM RD
ASHEVILLE, NC, 28806