



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13150-36-5158
State Number
23635

EQUIPMENT INSPECTED

State Number: 23635	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 102
Landings: 2	Installed: 03/23/2006	Rope Size: 0
Volts: 280	Complied: 03/23/2006	Entrances: 1
OWNER	OCCUPANT	
KINNET MEMORIAL BAPTIST CHURCH	KINNET MEMORIAL BAPTIST CHURCH	
1106 EAST MOREHEAD STREET	1106 EAST MOREHEAD STREET	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 05/30/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

none found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: DON PEGG 336-226-0838

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

KINNET MEMORIAL BAPTIST CHURCH
1106 EAST MOREHEAD STREET
BURLINGTON, NC, 27215