



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13150-36-5739
State Number
13791

EQUIPMENT INSPECTED

State Number: 13791	Type of Unit: Passenger	Floor to Floor: L to 3
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 4	Installed: 05/16/1990	Rope Size:
Volts: 208	Complied: 05/20/1990	Entrances: 1

OWNER

HOLIDAY INN EXPRESS
I-85 KIRKPATRICK
BURLINGTON, NC, 27215

OCCUPANT

HOLIDAY INN EXPRESS
I-85 KIRKPATRICK
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 05/30/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

none found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: ART WILLIAMS 336) 584-4447

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

HOLIDAY INN EXPRESS
I-85 KIRKPATRICK
BURLINGTON, NC, 27215