



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13156-48-5658
State Number
12791

EQUIPMENT INSPECTED

State Number: 12791	Type of Unit: Passenger	Floor to Floor: G to 15
Capacity: 2500	Manuf: OTIS	Speed: 200
Landings: 16	Installed: 05/09/1988	Rope Size: 5/8
Volts: 480	Complied: 06/10/1988	Entrances: 1
OWNER	OCCUPANT	
CAM	OCEAN POINT CONDO	
PO BOX 8126	ONE W OCEAN BLVD	
OCEAN ISLE BEACH, NC, 28469	OCEAN ISLE, NC, 28459	

INSPECTION INFORMATION

Inspection Date 06/05/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.13.1[f] Properly maintain hangers, tracks, door rollers, up-thrusts, and door safety retainers, where required. Replace worn car door gibs
2.27.3.1 Put the Phase I fire service feature in proper working order. NO AUDIO & FIRE HAT

Items must be corrected by: 06/25/2013

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Unavailable

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAM
PO BOX 8126
OCEAN ISLE BEACH, NC, 28469