



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13162-17-0533
State Number
6962

EQUIPMENT INSPECTED

State Number: 6962	Type of Unit: Freight	Floor to Floor: G to 4
Capacity: 11000	Manuf: OTIS	Speed: 100
Landings: 4	Installed: 08/23/1971	Rope Size: 5/8
Volts: 550	Complied: 09/07/1971	Entrances: 1
OWNER	OCCUPANT	
ASHEVILLE BUNCOMBE TECH COLL	ASHEVILLE BUNCOMBE TECH COMM COLLEGE	
340 VICTORIA RD	1459 SANDHILL RD.	
ASHEVILLE, NC, 28801	CANDLER, NC, 28715	

INSPECTION INFORMATION

Inspection Date 06/11/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.1.6.5	Provide a class ABC fire extinguisher in machinery space.Up dated.
8.11.2.2.2	Perform an annual no load safety test and provide proper tags.

Items must be corrected by: 07/11/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Eddie

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE BUNCOMBE TECH COLL
340 VICTORIA RD
ASHEVILLE, NC, 28801