



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**13162-17-597**  
State Number  
**4309**

### EQUIPMENT INSPECTED

State Number: <b>4309</b>	Type of Unit: Passenger	Floor to Floor: B to 3
Capacity: 3000	Manuf: OTIS	Speed: 300
Landings: 4	Installed: 02/19/1960	Rope Size: 5/8
Volts: 240	Complied: 02/19/1960	Entrances: 1
OWNER	OCCUPANT	
ASHEVILLE BUNCOMBE TECH COLL	ASHEVILLE BUNCOMBE TECH COMM COLLEGE	
340 VICTORIA RD	1459 SANDHILL RD.	
ASHEVILLE, NC, 28801	CHANDLER, NC, 28715	

### INSPECTION INFORMATION

Inspection Date 06/11/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

### VIOLATIONS

8.11.2.2.2	Perform an annual no load safety test and provide proper tags.
2.11	Anti-rotation for suspension ropes.

Items must be corrected by: 07/11/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Eddie

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE BUNCOMBE TECH COLL  
340 VICTORIA RD  
ASHEVILLE, NC, 28801