



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**13162-48-089**  
State Number  
**14837**

EQUIPMENT INSPECTED

State Number: <b>14837</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 11/16/1992	Rope Size:
Volts: 480	Complied: 12/07/1992	Entrances: 1
OWNER	OCCUPANT	
BLADEN CO HOSPITAL	BLADEN COUNTY HOSPITAL	
PO BOX 398	501 POPLAR ST	
ELIZABETHTOWN, NC, 28337	ELIZABETHTOWN, NC, 28337	

INSPECTION INFORMATION

Inspection Date 06/11/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	---------------------------------	--------------------------	------------------

9

VIOLATIONS

5.1.21.1	Put the in car alarm bell in working order.
2.26.2.7	Put the pit stop switch in working order.

Items must be corrected by: 07/01/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Thomas

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BLADEN CO HOSPITAL  
PO BOX 398  
ELIZABETHTOWN, NC, 28337