N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13162-48-4430
State Number
6961

EQUIPMENT INSPECTED

State Number: **6961**	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 08/05/1971	Rope Size:
Volts: 480	Complied: 08/05/1971	Entrances: 1

OWNER
ELIZABETHTOWN MIDDLE SCHOOL
P O BOX 639
ELIZABETHTOWN, NC, 28327

OCCUPANT
ELIZABETHTOWN MIDDLE SCHOOL
HWY 701 SOUTH
ELIZABETHTOWN, NC, 28337

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/11/2013	Routine	Re-issued	48 - Martin	BLADEN

9

VIOLATIONS

3.24.1 Elevator pumping unit. [OIL IN BOTTOM OF UNIT]

Items must be corrected by: 07/01/2013 Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Drew Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ELIZABETHTOWN MIDDLE SCHOOL
P O BOX 639
ELIZABETHTOWN, NC, 28327