



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13170-17-4793
State Number
18143

EQUIPMENT INSPECTED

State Number: 18143	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: SCHINDLER	Speed: 100
Landings: 2	Installed: 11/23/1998	Rope Size:
Volts: 480	Complied: 11/23/1998	Entrances: 1

OWNER

ARBOR TERRACE
3199 SWEETEN CREEK ROAD
ASHEVILLE, NC, 28803

OCCUPANT

ARBOR TERRACE
3199 SWEETEN CREEK ROAD
ASHEVILLE, NC, 28803

INSPECTION INFORMATION

Inspection Date 06/19/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.4.13.1[1]	Properly maintain door restrictors, where required.
8.6.4	Secure car interior handrails.

Items must be corrected by: 07/19/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: David 828-681-5533

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARBOR TERRACE
3199 SWEETEN CREEK ROAD
ASHEVILLE, NC, 28803