



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13172-52-3972
State Number
13063

EQUIPMENT INSPECTED

State Number: 13063	Type of Unit: Freight	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: SOUTHERN	Speed: 115
Landings: 5	Installed: 05/31/1989	Rope Size: 0
Volts: 208	Complied: 05/31/1989	Entrances: 2
OWNER	OCCUPANT	
ELK RIVER COUNTRY CLUB	ELK RIVERCLUB HOUSE	
1000 CLUBHOUSE DRIVE	235 CLUB HOUSE DRIVE	
BANNER ELK, NC, 28604	BANNER ELK, NC, 28604	

INSPECTION INFORMATION

Inspection Date 06/21/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

2.12.6.1	Replace or repair the damaged pull chain in the hoistway access box on the 1st floor.
2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.6.1.7.2	Provide the proper metal tag to the controller for all periodic tests.

Items must be corrected by: 07/01/2013

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Elk River 828-896-9773

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELK RIVER COUNTRY CLUB
1000 CLUBHOUSE DRIVE
BANNER ELK, NC, 28604