N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13177-48-0839
State Number
20567

EQUIPMENT INSPECTED

State Number: **20567**
Capacity: 2500
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: SCHINDLER
Installed: 12/03/2001
Complied: 12/03/2001

Floor to Floor: 1 to 2
Speed: 100
Rope Size:
Entrances: 1

OWNER
SECURITY SAVINGS BANK
P O BOX 10069
SOUTHPORT, NC, 28461

OCCUPANT
SECURITY SAVINGS BANK
300 HOWE ST
SOUTHPORT, NC, 28461

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/26/2013	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Phil Fravel

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
SECURITY SAVINGS BANK
P O BOX 10069
SOUTHPORT, NC, 28461