N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13177-48-2550
State Number
25517

EQUIPMENT INSPECTED

State Number: **25517**	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 06/03/2008	Rope Size:
Volts: 208	Complied: 06/03/2008	Entrances: 1

OWNER
ST JAMES SQUARE OF WILMINGTON
1508 MILITARY CUTOFF RD.
WILMINGTON, NC, 28403

OCCUPANT
ST JAMES OFFICE BLDG
4332 SOUTHPORT/SUPPLY RD SE
SOUTHPORT, NC, 28461

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/26/2013	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order. {All VIOLATIONS MUST BE REPAIRED BEFORE ABATEMENT DATE AND REPLY SENT TO RALEIGH VIA WEB SITE AT BOTTOM OF REPORT}

8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).

Items must be corrected by: 07/06/2013 Elevator Name: BLDG 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Unavailable Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ST JAMES SQUARE OF WILMINGTON
1508 MILITARY CUTOFF RD.
WILMINGTON, NC, 28403