



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13179-36-5023
State Number
19724

EQUIPMENT INSPECTED

State Number: 19724	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: MIM ELE	Speed: 100
Landings: 3	Installed: 03/14/2001	Rope Size:
Volts: 208	Complied: 03/27/2001	Entrances: 1
OWNER	OCCUPANT	
CAROLINA PROPERTIES HOLDINGS	CAROLINA PROPERTIES HOLDINGS	
200 B N MAIN STREET	200B N MAIN ST	
DURHAM, NC, 27701	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 06/28/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

none found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JASON COX 919-687-3506

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAROLINA PROPERTIES HOLDINGS
200 B N MAIN STREET
DURHAM, NC, 27701