N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13179-48-0577
State Number
H2175

EQUIPMENT INSPECTED

State Number: **H2175**
Capacity: 750
Landings: 2
Volts: 120

Type of Unit: Hand Lift
Manuf: TKE
Installed: 11/12/2009
Complied: 11/12/2009

Floor to Floor: 1 to 2
Speed: 20
Rope Size:
Entrances: 2

OWNER
FIRST BAPTIST CHURCH
521 MARTIN LUTHER KING JR ST
BLADENBORO, NC, 28320

OCCUPANT
FIRST BAPTIST CHURCH
521 MARTIN LUTHER KING JR ST
BLADENBORO, NC, 28320

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/28/2013	Routine	Re-issued	48 - Martin	BLADEN

9

VIOLATIONS

n/a Repair top run buttons

n/a Lub. Worm & gear for squeaking [ALL VIOLATIONS MUST BE REPAIRED BY ABATEMENT DATE AND REPLY SENT TO RALEIGH VIA WEB ADDRESS AT BOTTOM OF REPORT]

Items must be corrected by: 07/28/2013

Elevator Name: SANCTUARY

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Arey Robinson

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
FIRST BAPTIST CHURCH
521 MARTIN LUTHER KING JR ST
BLADENBORO, NC, 28320