



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13191-48-5360
State Number
24906

EQUIPMENT INSPECTED

State Number: 24906	Type of Unit: Passenger	Floor to Floor: 1 to 6
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 6	Installed: 06/25/2007	Rope Size:
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
SEASIDELANDING PARTNERS LLC	SEASIDE LANDING CONDOS	
7265 SEASHELL LANE	7265 SEASHELL LANE	
OCEAN ISLE BEACH, NC, 28469	OCEAN ISLE BEACH, NC, 28469	

INSPECTION INFORMATION

Inspection Date 07/10/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).

Items must be corrected by: 07/30/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SEASIDELANDING PARTNERS LLC
7265 SEASHELL LANE
OCEAN ISLE BEACH, NC, 28469