



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13192-48-3913
State Number
23065

EQUIPMENT INSPECTED

State Number: 23065	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 06/22/2005	Rope Size: .
Volts: 240	Complied: 06/22/2005	Entrances: 2
OWNER WATERWAY LANDING HOMEOWNERS ASS. 1135 PARK RD SUNSET BEACH, NC, 28468		OCCUPANT WATERWAY LANDING CONDOS 1135 PARK RD SUNSET BEACH, NC, 28468

INSPECTION INFORMATION

Inspection Date 07/11/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order. [ALL VIOLATIONS MUST BE REPAIRED BY ABATEMENT DATE AND REPLY SENT TO RALEIGH VIA WEB ADDRESS AT BOTTOM OF REPORT].

Items must be corrected by: 07/21/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: C. Loyd

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WATERWAY LANDING HOMEOWNERS ASS.
1135 PARK RD
SUNSET BEACH, NC, 28468