



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13193-16-4517
State Number
24439

EQUIPMENT INSPECTED

State Number: 24439	Type of Unit: Passenger	Floor to Floor: P to 3
Capacity: 2500	Manuf: TKE	Speed: 125
Landings: 4	Installed: 01/10/2007	Rope Size: 0
Volts: 230	Complied: 01/10/2007	Entrances: 2

OWNER
DAY BEACON HOA
PO BOX 1303
MANTEO, NC, 27954

OCCUPANT
DAY BEACON
326 E WATER STREET
BELLHAVEN, NC, 27810

INSPECTION INFORMATION

Inspection Date 07/12/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

2.2.5.1 Put the pit lights in proper working order.

Items must be corrected by: 08/11/2013

Elevator Name: D

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: J S Martin Property Manager

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DAY BEACON HOA
PO BOX 1303
MANTEO, NC, 27954