



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13199-8-1454
State Number
21244

EQUIPMENT INSPECTED

State Number: 21244	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 2	Installed: 09/04/2003	Rope Size: 0
Volts: 480	Complied: 09/04/2003	Entrances: 1
OWNER	OCCUPANT	
LANESBORO CORRECTIONAL INSTITUTION	LANESBORO CORRECTIONAL INSTITUTION	
P.O.BOX 280	552 PRISON CAMP RD	
POLKTON, NC, 28135	POLKTON, NC, 28135	

INSPECTION INFORMATION

Inspection Date 07/18/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County ANSON
-------------------------------	----------------------------	---------------------------------	-------------------------	-----------------

4

VIOLATIONS

NONE

Items must be corrected by: 08/17/2013

Elevator Name: RICHMOND BLDG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: ANDY BREWER 704-695-1013

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LANESBORO CORRECTIONAL INSTITUTION
P.O.BOX 280
POLKTON, NC, 28135