



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**13199-8-2392**  
State Number  
**17595**

EQUIPMENT INSPECTED

State Number: <b>17595</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 07/10/1998	Rope Size:
Volts: 480	Complied: 07/16/1998	Entrances: 1
OWNER	OCCUPANT	
SOUTH PIEDMONT COMMUNITY COLLEGE	SOUTH PIEDMONT COMMUNITY COLLEGE	
ATT: ACCTS PAYABLE	129 LEDBETTER ST	
POLKTON, NC, 28135	POLKTON, NC, 28135	

INSPECTION INFORMATION

Inspection Date 07/18/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County ANSON
-------------------------------	----------------------------	---------------------------------	-------------------------	-----------------

4

VIOLATIONS

.8.6.4.15 RESTORE ELEVATOR EMERGENCY PHONE

Items must be corrected by: 08/17/2013

Elevator Name: MARTIN BLDG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: THOMAS SUGGS 704-272-5362

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SOUTH PIEDMONT COMMUNITY COLLEGE  
ATT: ACCTS PAYABLE  
POLKTON, NC, 28135