



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13204-48-4338
State Number
19902

EQUIPMENT INSPECTED

State Number: 19902	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 3	Installed: 05/07/2001	Rope Size:
Volts: 208	Complied: 05/15/2001	Entrances: 1
OWNER	OCCUPANT	
SEATRAIL CORPORATION	SEA TRAIL CHAMPIONS BLDG. #34	
279 CLUBHOUSE RD	133 AVIAN DR	
SUNSET BEACH, NC, 28668	SUNSET BEACH, NC, 28668	

INSPECTION INFORMATION

Inspection Date 07/23/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.8.1	Clean the elevator machine room.
5.1.21.1	Put the in car alarm bell in working order.
2.27.1.1.2	Put the in car emergency telephone in proper working order.

Items must be corrected by: 08/22/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SEATRAIL CORPORATION
279 CLUBHOUSE RD
SUNSET BEACH, NC, 28668