



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13205-36-0681
State Number
28810

EQUIPMENT INSPECTED

State Number: 28810	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 3500	Manuf: TKE	Speed: 125
Landings: 4	Installed: 07/24/2013	Rope Size:
Volts: 460	Complied: 07/24/2013	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	ELON GLOBAL RESIDENCE HALLS BLDG 4	
CAMPUS BOX 2060	103 PHOENIX DRIVE	
ELON, NC, 27244	EKON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 07/24/2013	Type Inspection New	Certificate Status Issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	------------------------	------------------------------	---------------------------	--------------------

1

VIOLATIONS

THIS UNIT IS IN COMPLIANCE THIS DATE 7-24-2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: GARY Y

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
CAMPUS BOX 2060
ELON, NC, 27244