



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13205-48-1261
State Number
21563

EQUIPMENT INSPECTED

State Number: 21563	Type of Unit: Passenger	Floor to Floor: 3 to 2
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 1	Installed: 05/27/2003	Rope Size:
Volts: 208	Complied: 06/03/2003	Entrances: 0

OWNER

SEA TRAIL CORPORATION
279 CLUBHOUSE ROAD
SUNSET BEACH, NC, 28468

OCCUPANT

SEA TRAIL CAMPION #37
140 AVIAN DR.
SUNSET BEACH, NC, 28468

INSPECTION INFORMATION

Inspection Date 07/24/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

- 2.27.7.2 Provide the Phase II fire service instructions in the elevator.
- 2.27.3.1 Put the Phase I fire service feature in proper working order. [NO FIRE HAT IN CAR].
- 2.27.1.1.2 Put the in car emergency telephone in proper working order.
- 8.6.4.13.1[k] Properly maintain door closers, where required. [MOTOR ROOM DOOR]. [ALL VIOLATIONS MUST BE REPAIRED BY ABATEMENT DATE AND REPLY SENT TO RALEIGH VIA WEB ADDRESS AT BOTTOM OF REPORT].

Items must be corrected by: 08/23/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SEA TRAIL CORPORATION
279 CLUBHOUSE ROAD
SUNSET BEACH, NC, 28468