



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13205-48-384
State Number
23517

EQUIPMENT INSPECTED

State Number: 23517	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 3	Installed: 12/15/2005	Rope Size: .
Volts: 208	Complied: 12/15/2005	Entrances: 1
OWNER	OCCUPANT	
SEA TRAIL CORPORATION	SEA TRAIL CHAMPION BLDG #39	
279 CLUBHOUSE RD.	142 AVIAN DR	
SUNSET BEACH, NC, 28468	SUSNET BEACH, NC, 28468	

INSPECTION INFORMATION

Inspection Date 07/24/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

- 2.7.5.1 Put the machine room lights in working order.
- 2.27.1.1.2 Put the in car emergency telephone in proper working order.
- 8.6.4.13.1[k] Properly maintain door closers, where required. [MOTOR ROOM DOOR]. [ALL VIOLATIONS MUST BE REPAIRED BY ABATEMENT DATE AND REPLY SENT TO RALEIGH VIA WEB ADDRESS AT BOTTOM OF REPORT].

Items must be corrected by: 08/23/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SEA TRAIL CORPORATION
279 CLUBHOUSE RD.
SUNSET BEACH, NC, 28468