N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13206-16-2355
State Number
25676

EQUIPMENT INSPECTED

State Number: **25676**	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 06/16/2008	Rope Size: 0
Volts: 208	Complied:	Entrances: 1

OWNER
SELECT BANK AND TRUST
155 N MARKET ST
WASHINGTON, NC, 27889

OCCUPANT
GEORGE TOWNE OFFICE BLDG
155 N MARKET ST
WASHINGT0N, NC, 27889

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
07/25/2013	Routine	Re-issued	16 - Moore	BEAUFORT

7

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Sonny / Bank Manager Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
SELECT BANK AND TRUST
155 N MARKET ST
WASHINGTON, NC, 27889