



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13206-48-599
State Number
15684

EQUIPMENT INSPECTED

State Number: 15684	Type of Unit: Passenger	Floor to Floor: G to 2
Capacity: 2100	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 10/30/1995	Rope Size:
Volts: 208	Complied: 10/30/1995	Entrances: 1

OWNER
CASWLL PARTNERSHIP
OCEAN GREENS LANE
CASWELL BEACH, NC, 28465

OCCUPANT
OCEAN GREENS BLDG #2
55-58 FOX FIRE LN.
CASWELL BEACH, NC, 28465

INSPECTION INFORMATION

Inspection Date 07/25/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.7.1 Clean the elevator pit.

2.15.2 Replace the cracked, worn, or missing car guides. [ALL VIOLATIONS MUST BE REPAIRED BY ABATEMENT DATE AND REPLY SENT TO RALEIGH VIA WEB ADDRESS AT BOTTOM OF REPORT].

Items must be corrected by: 08/24/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CASWLL PARTNERSHIP
OCEAN GREENS LANE
CASWELL BEACH, NC, 28465