



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13210-48-5816
State Number
28841

EQUIPMENT INSPECTED

State Number: 28841	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: TKE	Speed: 110
Landings: 3	Installed: 07/29/2013	Rope Size:
Volts: 208	Complied:	Entrances: 1

OWNER

WESTGAYE SENOIR APTS
9200 OCEANGATE PLAZA EXT
LELAND, NC, 28541

OCCUPANT

WESTGAYE SENOIR LIVING ELEV 2
9200 OCEANGATE PLAZA EXT
LELAND, NC, 28541

INSPECTION INFORMATION

Inspection Date 07/29/2013	Type Inspection New	Certificate Status Not Issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	------------------------	----------------------------------	--------------------------	---------------------

10

VIOLATIONS

N/A UNIT FAILED - Caulking in motor room - Caulking in shaft - Condensation in motor room - Sump pump underrated - Low lighting outside elevators on all floors [1 fc of lighting and should be 10 fc lighting].

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Bob H.

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WESTGAYE SENOIR APTS
9200 OCEANGATE PLAZA EXT
LELAND, NC, 28541