



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13218-52-4829
State Number
6201

EQUIPMENT INSPECTED

State Number: 6201	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 1500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 08/13/1969	Rope Size: 0
Volts: 208	Complied: 11/20/2000	Entrances: 1

OWNER
LEES MCRAE COLLEGE
P.O. BOX 128
BANNER ELK, NC, 28604

OCCUPANT
LEES MCRAE COLLEGE
150 BUENA VISTA WAY
BANNER ELK, NC, 28604

INSPECTION INFORMATION

Inspection Date 08/06/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

8.6.5.5.2 Empty the drain bucket in the pit.

Items must be corrected by: 09/05/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Lees Mcrae College 828-898-8770

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LEES MCRAE COLLEGE
P.O. BOX 128
BANNER ELK, NC, 28604