

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-807-2770

Report Number 13238-48-3344 State Number 23405

EQUIPMENT INSPECTED

State Number: 23405	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 3	Installed: 10/12/2005	Rope Size:
Volts: 208	Complied: 10/12/2005	Entrances: 2
OWNER	OCCUPANT	
THE RED APPLE GROUP, LLC	RED APPLE PROFESSIONAL PARK	
712 VILLAGE ROAD	712 VILLAGE ROAD, SW	
SHALLOTTE, NC, 28470	SHALLOTTE, NC, 28470	

INSPECTION INFORMATION

Inspection Date 08/26/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THE RED APPLE GROUP, LLC
712 VILLAGE ROAD
SHALLOTTE, NC, 28470