N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13259-36-1927
State Number
8128

EQUIPMENT INSPECTED

State Number: **8128**	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 07/03/1975	Rope Size:
Volts: 440	Complied: 07/03/1975	Entrances: 1

OWNER
ALAMANCE-BURLINGTON SCHOOL SYSTEM
1712 VAUGHN RD
BURLINGTON, NC, 27215

OCCUPANT
NEWLIN ELEMENTARY SCHOOL
316 CARDEN ST
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
09/16/2013	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

none found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: office

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ALAMANCE-BURLINGTON SCHOOL SYSTEM
1712 VAUGHN RD
BURLINGTON, NC, 27215