



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13269-48-092
State Number
8103

EQUIPMENT INSPECTED

State Number: 8103	Type of Unit: Passenger	Floor to Floor: 1 to 6
Capacity: 6000	Manuf: SOUTHEASTERN	Speed: 200
Landings: 6	Installed: 10/22/1975	Rope Size: 5/8
Volts: 440	Complied: 03/13/2001	Entrances: 2
OWNER	OCCUPANT	
ARCHER DANIELS MIDLAND	ARCHER DANIELS MIDLAND	
EAST MOORE ST. EXT. - BLDG. 103	EAST MOORE ST. EXT. - BLDG. 103	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 09/26/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.2.5.1	Put the pit lights in proper working order.
8.6.4.7.1	Clean the elevator pit.

Items must be corrected by: 10/26/2013

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Gregory Skaggs

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARCHER DANIELS MIDLAND
EAST MOORE ST. EXT. - BLDG. 103
SOUTHPORT, NC, 28461