



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13281-8-0836
State Number
26610

EQUIPMENT INSPECTED

State Number: 26610	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 02/16/2009	Rope Size:
Volts: 208	Complied: 02/16/2009	Entrances: 1
OWNER	OCCUPANT	
BPR PROPERTIES	FAIRFIELD INN & SUITES	
341 S SWING ROAD	920 EXECUTIVE WAY	
GREENSBORO, NC, 27409	ASHEBORO, NC, 27203	

INSPECTION INFORMATION

Inspection Date 10/08/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

76

VIOLATIONS

8.6.4.15	RESTORE ELEV EMERGENCY LIGHTING
8.6.4.7	CLEAN OUT PIT

Elevator Name: VISITOR

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: DAVE WILLETS

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BPR PROPERTIES
341 S SWING ROAD
GREENSBORO, NC, 27409