N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13289-8-4221
State Number
5219

EQUIPMENT INSPECTED

State Number: **5219**
Capacity: 2500
Landings: 2
Volts: 240

Type of Unit: Passenger
Manuf: WESTBROOK
Installed: 07/19/1965
Complied: 05/20/2003

Floor to Floor: 1 to 2
Speed: 75
Rope Size:
Entrances: 1

OWNER
DAVID & JANET RICH
211 SUNSET AVE
ASHEBORO, NC, 27203

OCCUPANT
COLLECTORS ANTIQUE MALL
211 SUNSET AVE
ASHEBORO, NC, 27203

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
10/16/2013	Routine	Re-issued	8 - Burris	RANDOLPH

76

VIOLATIONS

8.6.4.15 RESTORE ELEVATOR EMERGENCY LIGHTS & ALARM BELL (BATTERY)
8.6.4.10 AJUST CAR GATE SW 2" MAX

Elevator Name: VISITOR

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: DAVID POLAND / JACK GORHAM Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
DAVID & JANET RICH
211 SUNSET AVE
ASHEBORO, NC, 27203