



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13291-36-5416
State Number
H2409

EQUIPMENT INSPECTED

State Number: H2409	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: TK	Speed: 30
Landings: 2	Installed: 09/21/2012	Rope Size:
Volts: 208	Complied: 09/21/2012	Entrances: 1
OWNER	OCCUPANT	
FAITH UNITED METHODIST CHURCH	FAITH UNITED METHODIST CHURCH	
1732 WEST DAVIS STREET	1732 WEST DAVIS STREET	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 10/18/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

Please note that the inspection that was performed on 9-23-2013, report number 13266-36-1968 was coded in error. This inspection report 13291-36-5416 has corrected the coding error and is now completed and certificate has been updated.

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: KENNETH ALDRIDGE 336-227-2991

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

FAITH UNITED METHODIST CHURCH
1732 WEST DAVIS STREET
BURLINGTON, NC, 27215