



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13294-47-3197
State Number
9472

EQUIPMENT INSPECTED

| | | |
|---------------------------|-------------------------|------------------------|
| State Number: 9472 | Type of Unit: Passenger | Floor to Floor: 1 to 3 |
| Capacity: 2500 | Manuf: ASHEVILLE | Speed: 100 |
| Landings: 3 | Installed: 05/16/1980 | Rope Size: |
| Volts: 208 | Complied: 05/16/1980 | Entrances: 1 |
| OWNER | OCCUPANT | |
| ALCO PROPERTY MANAGEMENT | ARROWHEAD APARTMENTS | |
| 35 UNION | 100 CHEERIO LANE | |
| MEMPHIS, TN, 38103 | ASHEVILLE, NC, 28803 | |

INSPECTION INFORMATION

| | | | | | |
|-------------------------------|----------------------------|---------------------------------|--------------------------|--------------------|------|
| Inspection Date 10/21/2013 | Type Inspection Routine | Certificate Status Re-issued | Inspector 47 - Helton | County BUNCOMBE | 11 B |
|-------------------------------|----------------------------|---------------------------------|--------------------------|--------------------|------|

VIOLATIONS

n/a No violations found

Elevator Name: FRONT ELEVATOR / # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Andrew Heman 828 298 9390

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALCO PROPERTY MANAGEMENT
35 UNION
MEMPHIS, TN, 38103