



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13294-47-3319
State Number
23383

EQUIPMENT INSPECTED

State Number: 23383	Type of Unit: Passenger	Floor to Floor: B to 3
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 01/26/2007	Rope Size: 0
Volts: 208	Complied:	Entrances: 2
OWNER	OCCUPANT	
21 BATTERY PARK, LLC	21 BATTERY PARK CONDOS	
C/O IPM CORP./ATTN: STEPHANIE CLARK	21 BATTERY PARK AVE	
ARDEN, NC, 28704-0580	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 10/21/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 47 - Helton	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------	------

VIOLATIONS

8.6.5.16.5	5 year full load overspeed valve test
------------	---------------------------------------

Items must be corrected by: 11/20/2013

Elevator Name: ELEVATOR # 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Stephanie Clark

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

21 BATTERY PARK, LLC
C/O IPM CORP./ATTN: STEPHANIE CLARK
ARDEN, NC, 28704-0580